



NOTE:
 1. REFER TO PRODUCT DATA SHEETS FOR SPECIFIC APPLICATION METHODS.
 2. WALL ASSEMBLY SHALL PROVIDE FOR A MAXIMUM DESIGN DEFLECTION OF L/360.

3. OPTIONAL CONTINUOUS INSULATION BOARD SHALL HAVE MINIMUM 1/4" WIDE x 1/8" DEEP GROOVES SPACED 12" ON CENTER. GROOVES SHALL BE ORIENTATED VERTICALLY WHEN INSTALLED. JOINTS SHALL BE 1/8" OR LESS AND CLOSED ON THE EXTERIOR SIDE USING MINIMUM 2 3/8" WIDE FIBERGLASS MESH TAPE.

The architecture, engineering, and design of the project using the Tremco CPG Inc. and USG products are the responsibility of the project's design professional. All products and systems must comply with local building codes and standards. This detail is for general information and guidance only and Tremco CPG Inc. and USG specifically disclaims any liability for the use of this detail. The project design professional determines, in its sole discretion, whether this detail or a functionally equivalent detail is best suited for the project. This detail is subject to change without notice. Contact Tremco CPG Inc. to ensure you have the most recent version.



Dryvit Technical Support: 800-556-7752

StucCoat One Coat® Securock® ExoAir 430 System

USG | **TREMCO**
SECUROCK® EXOAIR® 430
 Technical Support: 866-209-2404

Detail: Termination at Roof/Wall Intersection				File Name:
Drawn by: KAB	Checked by: BD/CB	Scale: NTS	Date: 4/2023	SCOC CI SE430 17
www.tremcocpg.com				

TREMCO
 Construction Products Group