



NewBrick®

Termination at Roof Stop Flashing

NOTE:

1. OUTSULATION PLUS MD SYSTEM SHOWN FOR ILLUSTRATIVE PURPOSES ONLY. REFER TO APPROPRIATE DRYVIT SYSTEM FOR LITERATURE SYSTEM INSTALLATION.
2. EXTEND ROOF STOP FLASHING 1" (25 MM) MINIMUM BEYOND FACE OF NEW BRICK.
3. ROOF STOP TO BE MADE FROM CORROSION RESISTANT MATERIAL MIN. 24 GAUGE WITH WATER TIGHT SEAMS.
4. EXTEND ROOFING UNDERLAYMENT 5" (127 MM) UP VERTICAL WALL BEHIND METAL FLASHING.

The architecture, engineering, and design of the project using the Dryvit products is the responsibility of the project's design professional. All systems must comply with local building codes and standards. This detail is for general information and guidance only and Dryvit specifically disclaims any liability for the use of this detail and for the architecture, design, engineering or workmanship of any project. The project design professional determines, in its sole discretion, whether this detail or a functionally equivalent detail is best suited for the project. Use of a functionally equivalent detail does not violate Dryvit's warranty. This detail is subject to change without notice. Contact Dryvit to ensure you have the most recent version.

